




SAFETY CERTIFICATE

The school building of Aadhunik Public Senior Secondary Tapovan road Sidhbari in Tehsil Dharmshala Distt. Kangra H.P. was inspected by the concerned Junior Engineer. As per the report of Junior Engineer this building has neither been designed nor been constructed by this office. No earthquake resistant norms have been adopted for this building. No structural drawings approved by the competent Govt. agency have been produced. The structure is a Non-Engineered Structure. Hence the structural safety of this building cannot be ensured specifically from earthquake point of view. This department will not be responsible for any type of loss of life and property etc. if this structure fails under any circumstances. However as per visual inspection the building has been found to be safe at present only. This certificate is valid for academic session for 2025-26 .


Junior Engineer
HP.PWD Sub Division .II
Dharmshala .


Assistant Engineer,
HPPWD Sub Division. II
Dharmshala.


Executive Engineer
Dharmshala Division
HPPWD Dharmshala

Place: Dharamshala

Dated:

Himachal Pradesh
Public Works Department

NO.PW/DD/CB/WAB/B-17/2025


9693-94

Dated:-

27-01-2025

✓ Copy forwarded to the Manager, Aadhunik Public School Sidhbari, Tehsil Dharamshala, Distt. Kangra H.P. for information with reference to his application dated 15-01-2025 please.

Copy forwarded to the Assistant Engineer, Dharamshala Sub-Division No.II, HPPWD, Dharamshala for information with reference to his office letter No. 1181 dated 24/01/2025.


Executive Engineer,
Dharamshala Division,
HPPWD, Dharamshala