




SAFETY CERTIFICATE

The school building of AAdhunik Public School (Senior secondary) Tapovan road Sidhbari in Tehsil Dharamshala Distt. Kangra H.P. was inspected by the concerned Junior Engineer. As per the report of Junior Engineer this building has neither been designed nor been constructed by this office. No earthquake resistant norms have been adopted for this building. No structural drawings approved by the competent Govt. agency have been produced. The structure is a Non-Engineered Structure. Hence the structural safety of this building cannot be ensured specifically from earthquake point of view. This department will not be responsible for any type of loss of life and property etc. if this structure fails under any circumstances. However as per visual inspection the building has been found to be safe at present only. This certificate is valid for academic session for 2024-25 .


Junior Engineer
HP.PWD Sub Division .II
Dharmshala .


Assistant Engineer,
HPPWD Sub Division. II
Dharmshala.


Executive Engineer
Dharmshala Division
HPPWD Dharmshala

Place: Dharamshala

Dated:

Himachal Pradesh
Public Works Department


No. PW/DD/CB/WAB/B-17/2024

14235-36

Dated:- 09-02-2024

✓ Copy forwarded to the Manager, Aadhunik Public School Sidhbari, Tehsil Dharamshala, Distt. Kangra, H.P. for information with reference to his application No. APS/Misc/03/2024 dated 3-2-2024` please.

Copy forwarded to the Assistant Engineer, Dharamshala Sub-Division No.II, HPPWD, Dharamshala for information with reference to his office letter No. 1526 dated 8-2-2024.


Executive Engineer,
Dharamshala Division,
HPPWD, Dharamshala